




EGY- CRETE CEMENT PRODUCTS

PRE QUALIFICATIONS



01033325044 - 01033325055

01033324747 - 01033324088



WWW.EG-CRETE.COM



SALES@EG-CRETE.COM

PROJECT PARTNERS



CITY GATE NEW CAIRO DEVELOPMENT TRANSMITTAL FORM (Manufacturer's Data)



WBS (Package) CP02.02

TRANSMITTAL NO. CP02.02-TR-MD-0447

CONTRACT NO. 55016112

REV. 00

CONTRACT CONSTRUCTION OF INFRASTRUCTURE, ROADS, UTILITY BUILDINGS AND LANDSCAPE - PHASE 0

CONTRACTOR Concord for Engineering & Contracting S.A.E

TO: Turner Construction International Egypt for Project Management [TIME]

WE ARE SENDING	SUBMITTED FOR	SUBMITTAL STATUS CODE
☒ MD - Manufacturer's Data	☒ Approval	A - Approved
	☐ Information	B - Approved As Noted
		C - Revise and Resubmit
		D - Rejected and not to Resubmit
		Inf - For Information

ITEM	SPECIFICATION or DRAWING NO.	COPIES	DATE	DESCRIPTION	STATUS
1	Side Walks Section 02775 GRANIX	1	21/12/2025	GRANIX EGYCRETE IS A VENDOR LIST -TECHNICAL DATA SHEETS -SAMPLES for Finish Codes : PAV-GC-01 & PAV-GC-02 Sizes : 40*40 - 40*20 - 20*20 - 20*10 cm ² @ 6cm Thickness	

Prepared By

Signature 

Date



Received By

Signature

Date


RESPONSE / REMARKS

- initially approved as per the previous approved in project .
- final approval subject to mockup in site .
- chamfer for granix must be uniform for all sizes.
- recent test result required and must achieve specs requirements section 2780 clause 1.4 .

refer to the attached comments

Follow the attached drawing

Mr Mohamed El-Sirgany - Turner
International Middle East
Feb 23, 2026, 7:55 AM GMT+2:00

Action By
Signature 
Date Jan 1, 2026, 10:41 AM GMT+2:00

Received By

Signature

Date

Distribution: QDE ☐ PM/CM ☐ SUPERVISION CONSULTANT ☐

PROJECT PARTNERS



TIME EGYPT		CITY GATE NEW CAIRO DEVELOPMENT TRANSMITTAL FORM				ECG ENGINEERING CONSULTANTS GROUP S.A.	
WBS (Package)	CP19.02	TRANSMITTAL NO.				CP19.02-TR-0654	
CONTRACT NO.	55016717	Rev.				01	
CONTRACT	Construction of Infrastructure, Roads & Landscape Works for Zones 3D, 2D-D, 2D-7 and Villas for Zones 2D-D, 2D-7 & 3D-7						
CONTRACTOR	Consolidated Contractors Group S.A.L. (Offshore) (CCC)						
TO: Turner Construction International Egypt for Project Management [TIME]							
WE ARE SENDING		SUBMITTED FOR		SUBMITTAL STATUS CODE			
☐ Shop Drawing		☒ Approval		A - Approved			
☐ Manufacturer's Data		☐ Information		B - Approved As Noted			
☒ Material Sample				C - Revise and Resubmit			
☐ Guarantee / Warranties / Certificates)				D - Rejected and not to Resubmit			
☐ Operation & Manuals				Inf - For Information			
☐ As-Built Drawing							
☐ Other Technical Submittals							
ITEM	SPECIFICATION or DRAWING NO.	DOCUMENT REFERENCE NO.	COPIES	DATE	DESCRIPTION	STATUS	
1	1271-CP19.02-RFI-ARCH-0075	1271-CGP-MAR-0180	2&Soft	1-Oct-2025	Granix Interlock (EGY-CRETE) 1- Samples Handed over 11-09-2025 (to be used as the project control sample)	B	
Prepared By				Received By			
Signature				Signature			
Date				Date			
RESPONSE / REMARKS							
TIME reply: Find attached approved sample. 07 OCT 2025 2:30 PM RECEIVED RECEIVED 07 OCT 2025 CCC-CGP DCG ECG ENGINEERING CONSULTANTS GROUP S.A. City Gate Project (Project No: 3122) B: APPROVED AS NOTED WORK MAY PROCEED SUBJECT TO INCORPORATION OF CHANGES INDICATED By: H. Nagm Date: 7/10/2025							
Action By				Received By			
Signature				Signature			
Date				Date			
Distribution:				SUPERVISION CONSULTANT			

LMD°			1-Ninety Project	
-------------	---	---	-------------------------	---

MATERIAL SUBMITTAL FORM – (MAR)	
Contract No.: PEG 1145	Package No.: CP01

TO: Eng. Mohamed Kamel Senior Project Manager, Hill international	SUBMITTAL NO: PEG-1145-CP01-A01-LDS-CN-LS-MAR-0002
FROM: Eng. Tamer Hegab Chief Technical Officer, LMS construction	DATE: 30 Oct 2024
TITLE: Interlock and curbstone (EGYCRETE)	REVISION NO: Rev.: 02
	C/REF.:

MATERIAL SUBMISSION DESCRIPTION	
Discipline: ☐ C-CIVIL ☐ S-STRUCTURAL ☒ A-ARCHITECTURAL ☐ E-ELECTRICAL ☐ M-MECHANICAL ☐ O-OTHER	
Description of Material: Side Walk Interlock and curbstone	
Manufacturer: EGYCRETE	Supplier / Local Agent: EGYCRETE
Specification: Nil	BOQ Ref: Nil
Description of Attachments: 1- Reply on Consultant Comments on Rev.01 2- Area of Application 3- Updated BOQ 4- Technical Data Sheet 5- Test Reports 6- Oko Plan Approval 7- Method of Statement	
Description of Samples: Approved Sample from Oko Plan	
Specification Comparison Sheet: N/A	
Comparison in case of Alternative Submittal: N/A	

Date: 30 Oct 2024

Eng. Tamer Hegab

CONTRACTOR SIGNATURE:

Prepared By: 

	Consultant Receive:  Sector 3 30 OCT 2024 one ninety	Returned From Consultant: 	Contractor Receive: 
---	--	--	---

LMD°		 LMS CONSTRUCTION	1-Ninety Project	
-------------	---	---	------------------	---

MATERIAL SUBMITTAL FORM - (MAR)

Contract No.: PEG 1145

Package No.: CP01

EMPLOYER'S COMMENTS - (Optional)

Name:

Signature:

Date:

PROJECT MANAGEMENT CONSULTANT'S REVIEW - (Hill International)

Name: *Muhamad Saber*

Signature: *[Signature]*

Date: *5-11-2024*

As noted

SUPERVISION CONSULTANT'S COMMENTS

☐ A-APPROVED ☒ B -APPROVED AS NOTED, WORK MAY PROCEED - INCORPORATE COMMENTS ☐ C- REVISE / RESUBMIT ☐ D- REJECTED

- work should be done according to project specification Bsq, ECP approved shop drawing and manufacturer recommendation.
- approved for interlock.
- supplied materials should be tested before starting in site implementation according to the required stress for curbstone in project specification. otherwise curbstone shall be verified according E.G.P specs

For & On behalf of (Sabbour)

[Signature]
Reviewer

04-11-2024
DATE

[Signature]
PROJECT MANAGER

[Signature]
DATE

SUBMITTAL NO.: PEG-1145-CP01-LDS-CN-LS-MAR-0002 REVISION NO: Rev.: 02

PROJECT PARTNERS



MIDAR		ÖKOPLAN LANDSCAPING		CURVE LANDSCAPE		HILL International	
MATERIAL SUBMITTAL FORM نموذج تقديم اعتماد المواد / الخامات							
Contract No.: PEG-1170				Package No.: CP66			
TITLE (الموضوع): اعتماد عينة أنترلوك 20*20 سم				SUBMITTALNO: 1170-CP66-CN-CUR-MAR-067 الرقم			
TO (موجه الي): HILL International				DATE: 27-AUG-2023 (تاريخ التقديم)			
FROM (موجه من): CURVE Landscape				REVISION NO: Rev. 00			
ATTN.(عناية): Eng.Mohamed Ebrahim				C/REF.:			
MATERIAL SUBMISSION DESCRIPTION وصف المواد / الخامات المقدمة							
Discipline: ARCH							
Description of Material: اعتماد عينة أنترلوك 20*20 سم رمادي فاتح							
Manufacturer (Name & Address) EGY-CRETE المصنع (الاسم و العنوان)				Supplier / Local Agent EGY-CRETE المورد / الوكيل المحلي			
Specification مرجع وثيقة الضبط / المواصفة				BOQ Ref:			
Description of Attachments: وصف المرفقات				Description of Samples: 1-sample وصف العينات			
Specification Comparison Sheet ورقة مقارنة المواصفات							
Comparison in case of Alternative Submittal المقارنة في حالة تقديم بديل							
CONTRACTOR SIGNATURE توقيع المقاول: <i>A. Moneb</i>							
Hill Receive: ختم إستلام شركة هيل		Consultant Receive: ختم إستلام شركة الاستشاري		Returned From Consultant: ختم إستلام هيل لرد شركة الاستشاري		Contractor Receive: ختم إستلام المقاول الرد النهائي	
CLIENT'S COMMENTS (optional) / EIMOSTABAL CITY' COMMENTS رد المالك / شركة المستقبل							
Document Control & Archiving Procedure Mostakbal City Project							

PROJECT PARTNERS



MIDAR	ÖKOPLAN LANDSCAPING	CURVE LANDSCAPE	HILL International
--------------	-------------------------------	---------------------------	------------------------------

MATERIAL SUBMITTAL FORM
نموذج تقديم اعتماد المواد / الخدمات

Contract No.: PEG-1170 Package No.: CP66

Name: _____ Signature: _____ Date: _____
إسم وتوقيع ممثل المالك

PROJECT MANAGEMENT CONSULTANT'S REVIEW (optional) رد شركة هيل

Name: _____ Signature: _____ Date: _____
إسم وتوقيع هيل

CONSTRUCTION SUPERVISION CONSULTANT'S COMMENTS رد إشرافي الإشراف

لا مانع من اعتماد العيب على أن يتم تقديم اختبار رابطة للحامات
من أول توريد يتم للموقع من الخامات المعتمدة والعنيد
المعتمدة حسب المواصفات الفنية للمشروع ويتم مطابقتها بالعينات
المعممة ما لا يقل عن 10% من إجمالي المواد المستخدمة

☐ A-APPROVED معتمد ☒ B-APPROVED AS NOTED, WORK MAY PROCEED - INCORPORATE COMMENT معتمد مع مراعاة الملاحظات ☐ C- REVISE / RESUBMIT إعادة التقديم ☐ D- REJECTED مرفوض ولا يتم تقديمه مرة أخرى

For & On behalf of (إسم وتوقيع ممثل شركة الإشراف) _____
Name: Ahmed Elsayed Signature: _____ Date: 30/8/2023

PROJECT PARTNERS



EMAAR
MISR



Issue Date: 9/12/2024 12:34:41 PM

EMAAR
MISR

EMAAR MISR FOR DEVELOPMENT

PURCHASE ORDER

H/Q at Emaar Misr Sales Center
PO Box 229 Mokattam
Cairo . EG

Phone : +202 2 2503 2000

Fax : +202 2 2503

2020

Supplier Name: Egycrete	Standard Order No FM-PO-134	Revision No: 0
Address : 0	Date : 20-Jul-25	
	Revision Date :	
	Delivery Date: within 45 working days	
Contact Name: E. Ahmed	Description: EM-MIV-FM Supply of Granite/Granix required for Boulevard	
Telephone : 01098706853	Warranty Period: 15 months from Delivery	
Bill To : Mivida, Mivida MIVIDA	Ship To: Emaar FM Projects	Emaar FM Projects,cairo-New FM Uptown Cairo Cairo
Payment Terms: 50% Down Payment against guarantee Check , 50% after Delivery		
Note to Supplier : The price includes all taxes, Value added tax, insurances, social insurance. Duties , Customs , Levies Charges, Stamps , Stamp duties and all other costs and expenses necessary to comply with applicable laws"		
+Invoice to be handed to E. Ahmed Elsheikh -Miv- FM		
This is subject to Emaar Misr Terms and Condition of Purchase Order of Goods and Services (as below)		

Sr.NO	Pr NO	Item Code	Description of Goods/Services	UOM	Qty.
1	FM-PR-86		Gray Granix - Crushed stones to be darker and the lighter crushed stones to be reduced - Hond	MTR	34
2	FM-PR-86		Gritty Light - Color to be less yellow and into beige - Textured - SB	MTR	90
3	FM-PR-86		Gritty Dark color as sample received - Hond	MTR	70
4	FM-PR-86		Gray Granix - Crushed stones to be darker and the lighter crushed stones to be reduced - Hond	MTR	5
5	FM-PR-86		Gritty Light - Color to be less yellow and into beige - Textured - SB	MTR	12
6	FM-PR-86		Gray Granix - Crushed stones to be darker and the lighter crushed stones to	MTR	6



PROJECT PARTNERS



EMAAR
MISR



Issue Date: 9/12/2024 12:34:41 PM

Sr.NO	Pr NO	Item Code	Description of Goods/Services	UOM	Qty.
			be reduced - Hond		
7	FM-PR-86		Gritty Light - Color to be less yellow and into beige - Textured - SB	MTR	15
8	FM-PR-86		DELIVERY FLAT FEE	MTR	1

Note All Goods / Services supplied are subject to inspection and acceptance.
All terms & conditions mentioned overleaf are an integral part of this purchase order.

Authorized by:

Wahid
23 July 2025

Dahi
23/7/2025

GENERAL TERMS & CONDITIONS OF PURCHASE ORDER

- DEFINITIONS:** The term EMAAR MISR shall mean the entity issuing this purchase order. The entity to whom this purchase is directed and issued shall be termed the Supplier/ Contractor.
The term Delivery Date: means the date or dates specified in the Purchase Order by which Supplier is required to deliver the Work, goods, Services / handover.
The term Works/Products/Deliverables: means the deliverables specified in the Purchase Order or any Scope of Work to be delivered before/on the Delivery Date.
The term Scope of Work (SOW): means all documents, specifying without limitation the supplier/ contractor specific scope of work and the time frame of the Works that supplier / contractor will perform and deliver for EMAAR MISR.
- ACCEPTANCE:** The Supplier/contractor must sign and stamp the Purchase Order Documents to indicate its acceptance thereof, and return the original signed and stamped document to EMAAR MISR within two (2) working days from its receiving date by hand or by email. Should the Supplier fail to do so, EMAAR MISR shall be entitled to proceed with purchasing from other suppliers and the documents sent to the Supplier shall be considered null and void.
- AMENDMENTS:** This purchase order may be modified or amended only in written form signed by both parties and their duly authorized representatives.
- PAYMENT/EXTRAS:** Supplier will be paid in accordance with prices, basing points and other terms set forth in the purchase order Annex (1) or as duly amended, and unless specified therein, no additional charges or extras will be allowed or paid by EMAAR MISR, including without limitation, additional charges for freight, express, loading, unloading, cartage expediting, pallets, insurance or storage.



PROJECT PARTNERS



Mostakbal City...



APROX

ENGINEERING SOLUTIONS

Purchase Order

Project name: Mostakbal city zone (S-1.1)

PO No: 32

Date: 28/09/2025

To Company: EGY-CRETE

Attention: Eng. Mohamed Salem

Title: Sales Engineer

Tel: +20303325044

Cell No: +20115637757

Ref. Quot. No: EGY-CR14/180605/303

Order: 22/09/2025

Local Purchase	1
Foreign Purchase	

From:	APROX Engineering Solutions
To:	+2022790226
Ref:	
Requested Dept:	Procurement
Contact Name:	Omar Adel
Title:	Senior Procurement Engineer
Cell No:	+20155675097

Invoicing to be made to the name of "APROX"

Invoices to be addressed, with PO reference and delivery notes, to "APROX"

55 Moez El Dawla St., Nasr City, Cairo

Purchase order is subject to General Conditions shown overleaf and additional conditions detailed herewith. Please supply the following:

Item No.	Description	Unit	Vendor	General code	BOQ code	Cc/	Price/Item	Total Price	Remarks
1	Interlocking concrete block pavers, (400X400X60mm), Dark Gray Color, Antique brushed finish, with strength 350 kg/cm2.	m³	EGY-CRETE			142			
2	Interlocking concrete block pavers, (400X400X60mm), Medium Gray Color, Antique brushed finish, with strength 350 kg/cm2.	m³	EGY-CRETE			48			
3	Interlocking concrete block pavers, (400X400X60mm), Light Gray Color, Antique brushed finish, with strength 350 kg/cm2.	m³	EGY-CRETE			290			
4	Interlocking concrete block pavers, (200X200X60mm), Dark Gray Color, Antique brushed finish, with strength 350 kg/cm2.	m³	EGY-CRETE			23			
5	Interlocking concrete block pavers, (200X200X60mm), Medium Gray Color, Antique brushed finish, with strength 350 kg/cm2.	m³	EGY-CRETE			116			
6	Interlocking concrete block pavers, (200X200X60mm), Light Gray Color, Antique brushed finish, with strength 350 kg/cm2.	m³	EGY-CRETE			158			
Sub Total									
Shipping Cost									
Total (Including Shipping)									
VAT (11%)									
Grand Total									

Payment and Delivery terms:



Payment Terms: 50% cash on delivery, 50% cheque post-dated 21 days

Delivery location: Mostakbal City, New Cairo, Egypt

Delivery Time: to be arranged with site

Sub Total	
Withheld e.g. Tax (15%)	
Total Amount (incl. Sales Tax)	

Purchasing section:

#	Commercial Engineer (Prepared by)	Commercial Manager (Reviewed by)
Name	Omar Adel	Rasha Yahia
Signature		

28/9
2025



PROJECT PARTNERS



Mostakbal City...



امرتوريد
Purchase Order
PO-0080-CV-0062

Date : 2025-08-11

اعداد احمد امين

To:	ابو كريت	المسادة
Name:	م/ محمد سالم	الاسناد
Phone Number:	01115619997	رقم الموبايل
Site:	المستقبل سوي	المشروع
Subject:	برندورة و انترلوك	الموضوع

تحيه طيبه وبعد ...

بالاشارة الى الموضوع عاليه وعرضكم المقدم لنا بتاريخ 11-08-2025 برجاء من سيادكم توريد الاتسي :

Sr. م	المبيان Description	الوحدة Unit	الكمية Qty	سعر الوحدة جم Price/unit	الاجمالى جم Total	ملاحظات
1	انتر لوك مربع 6x20x20 سم رمادي فاتح اجهاد 350 طبقا للعيونة المعتمدة	م2	275			
2	انتر لوك مربع 6x20x20 سم رمادي وسط اجهاد 350 طبقا للعيونة المعتمدة	م2	110			
3	حانتر لوك مربع 6x40x40 سم رمادي فاتح اجهاد 350 طبقا للعيونة المعتمدة	م2	180			
4	انتر لوك مربع 6x40x40 سم رمادي غامق اجهاد 350 طبقا للعيونة المعتمدة	م2	80			
اجمالى المبلغ						
طريقة القيمة المضافة 14%						
خصم ضريبة 1% ارباح تجارية وصناعية						
الصافي بعد الضرائب						
تم التوريد						
الاسعار شاملة النقل للموقع وغير شاملة التعتيق						
مخازنا بموقع المتقبل سوي						
ابو كريت						
مدة التوريد						
النقل						
مكان التسليم						
اسم المصادرة الشيكات						
شروط السداد						
الدفعات المتفق عليها						
100% دفعة مقدمة						
0% بعد التوريد						
0% شيك اجل 30 يوم						
EGP -						
EGP -						
مدير المشتريات						
مدير المكتب الفني						

يعتمد

18/8/25

18/8/25

V Y E

SODIC

Zuhair Fayed Partnership
Consultants, Engineers
and Information Systems

APROX
ENGINEERING SOLUTIONS

MATERIAL SUBMITTAL (MS)

Project Name	: 464Feddans – VYE (1,2,3) & Hub	Date	: 03/02/2025
Employer	: SODIC	Submittal No.	: VYE-MS-APROX-ARCH -0008-01
SR.Project Manager	: ENG. AHMED MOUSTAFA	Contract	: 500-001-CC-P11
Consultant	: Zuhair Fayed Partnership	From	: APROX Engineering Solutions
Contractor	: APROX Engineering Solutions	To	: Zuhair Fayed Partnership

Material/Equipment Description : interlocking precast (EGY-CRETE)

Location: VYE1,2,3,THE HUB

Submittal Category:

- | | | |
|---|---|---|
| ☒ Architecture – (ARCH) | ☐ Civil/Structure – (ST) | ☐ Survey – (SURV) |
| ☐ MEP – (MEP) | ☐ Fire Protection – (FP) | ☐ Plumbing – (PL) |
| ☐ HVAC – (HVAC) | ☐ Electrical – (ELECT) | ☐ Light Current – (E-LC) |
| ☐ Infrastructure – (INFRA) | ☐ Mobilization – (MOB) | ☐ Landscape – (LS) |
| ☐ Safety – (SAF) | ☐ Elevators – (ELEV) | ☐ General – (GEN) |

Spec. Reference	: all construction items	B.O.Q Reference	: 2.6.121	Quantity (-----)
Manufacturer	: EGY-CRETE	Date of arrival on site	: N/A	
Model Number	: N/A	Serial number	: N/A	
Country of Origin	: EGYPT	Certificate of origin	: N/A	
Storage Location	: NA	Bill of lading	: N/A	

Attachments:

☒ Hard Copy (A4 40) Sheets ☐ Soft Copy ☐ Samples (8)

Note: Please Clarify the Attachments if any.

Action Code Legend:

(A) Approved (B) Approved as Noted (C) Revise and Resubm (D) Rejected

Notes:

- Production, supply and /or implementation shall proceed only when action code is A / or B.
- Regarding action code C, resubmittal shall be within the limit set in the contract.
- Review does not relieve the contractor from responsibility of compliance with all requirements of contract documents.
- If rejected please see comments.

Consultant Comments:

Approved only for colors medium grey & Light Beige & Medium Beige & Brown subject to:
 * Approval for shop drawings.
 * Approval for tests.
 * Approval for Mock-up on site.
 * Approval for material statement.

M. Shaker
8/2/2025

Engineer

SODIC Document Control Department - Material Submittal (MS)



VYE

SODIC

Zuhair Fayez Partnen
Consultants
Architecture, Engineering
and Information Systh

APROX
ENGINEERING SOLUTIONS

MATERIAL SUBMITTAL (MS)

Project Name	: 464Feddans – VYE (1,2,3) & Hub	Date	: 31/12/2024
Employer	: SODIC	Submittal No.	: VYE-MS-APROX-ARCH-0008-00
SR.Project Manager	: ENG. AHMED MOUSTAFA	Contract	: 500-001-CC-P11
Consultant	: Zuhair Fayez Partnership	From	: APROX Engineering Solutions
Contractor	: APROX Engineering Solutions	To	: Zuhair Fayez Partnership Consultants

Material/Equipment Description : interlocking precast (EGY-CRETE)

Location: VYE1,2,3,THE HUB

Submittal Category:

- | | | |
|---|---|--|
| ☒ Architecture – (ARCH) | ☐ Civil/Structure – (ST) | ☐ Survey – (SURV) |
| ☐ MEP – (MEP) | ☐ Fire Protection – (FF) | ☐ Plumbing – (PL) |
| ☐ HVAC – (HVAC) | ☐ Electrical – (ELECT) | ☐ Light Current – (E-L.C) |
| ☐ Infrastructure – (INFRA) | ☐ Mobilization – (MOB) | ☐ Landscape – (LS) |
| ☐ Safety – (SAF) | ☐ Elevators – (ELEV) | ☐ General – (GEN) |

Spec. Reference	: all construction items	B.O.Q Reference	: 2.6.121
Manufacturer	: EGY-CRETE	Date of arrival on site	: N/A
Model Number	: N/A	Serial number	: N/A
Country of Origin	: EGYPT	Certificate of origin	: N/A
Storage Location	: NA	Bill of lading	: N/A

Attachments:

- ☒ Hard Copy (A4 17-1 CATALOG) Sheets ☐ Soft Copy ☐ Samples (15)

Note: Please Clarify the Attachemts if any.

Action Code Legend:

- (A) Approved (B) Approved as Noted (C) Revise and Resubm (D) Rejected

Notes:

- Production, supply and/or implementation shall proceed only when action code is A / or B.
- Regarding action code C, resubmittal shall be within the limit set in the contract.
- Review dose not relieve the contractor from responsibility of compliance with all requirments of contract documents.
- If rejected please see comments.

Consultant Comments:

**Samples are rejected for colors and new samples should be submitted for approval.*

APROX
22 JAN 2025
Received

M. Shaker
22/1/2025

Engineer

APROX

PROJECT PARTNERS

Submittal for approval of materials

Date: 20/01/2020

Request no:

SOD-MAT-AAR-0341 Rev 03

Project no. & title: Project No.E16104-0400S/T-04 Ministerial Buildings On Plot 9B&10B

Employer:	Engineer: dar	Contractor: SG El Soadaa Group
-----------	-------------------------	---

1. Material description (one item only on this form):

بلاط الرصف الخرساني (انترلوك)

1 CD

no SAMPLE

Area of application: اعمال الموقع العام

Drawing ref.: N/A

B.O.Q. ref. no.: 2780

Specification Ref.: 2780

Standards: N/A

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name: EGY-CRETE

Address: 17 SUADI COMPANY BUILDING NOZHA STREET GOLF - EGYPT

Local agent: SHEROUK FOR CEMENT PRODUCTS

dar Dar Al-Handasah

Project No.: E16104-0400S

3. Delivery:

Country of origin: EGYPT

Availability

☒ Locally Manufactured

☐ Overseas

Delivery: Ex-works/ total duration

Estimated time of arrival on site

Program: Date material required on site

Latest date for order

Received	Distribution	Action	In
A. Kh			
A. Ram			
H. B			

We certify that the above submitted items have been reviewed in detail and are correct and in full conformity with the Contract drawings and specifications

Submitted by: Eng. Mena

Signature: *(Signature)*
El Soadaa Group
(Construction and Building)

4. Engineer's Representative comments:

Subject to approval workshop at site with the required clear & shape. Additional tests going delivery.

☒ Approved

☒ Approved as noted

☐ Revise and resubmit

☐ Rejected

☐ Sample required

☐ Tests required


☐ Additional information required

☐ Manufacturer's guarantee required

Signature: A. Ro

Date: 28/1/20

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.



PROJECT PARTNERS

Submittal for approval of materials

dar 28 JUL 2019
RECEIVED Date: 28/07/2019
Request no: 104-0400S Time: SOD-MAT-AAR-0342 Rev 00
Proj. No. E16104-0400S

Project no. & title: **Project No.E16104-0400S/T-04 Ministerial Buildings On Plot 9B&10B**

Employer:	Engineer: dar	Contractor: SG El Soadaa Group
-----------	-------------------------	---

1. Material description (one item only on this form):

البريدرات الخرسانية سابقة الصب
1 CD
1 SAMPLE

Area of application: **All Building**
Drawing ref.: **N/A**
Specification Ref.: **2771**
B.O.Q. ref. no.: **2771**
Standards: **N/A**

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name: **EGY-CRETE**
Address: **المنطقة الصناعية مدينة بدر**
Local agent: **SHEROUK FOR CEMENT PRODUCTS**

3. Delivery:

Country of origin: **EGYPT**
Availability: ☒ Locally Manufactured ☐ Overseas

Delivery: Ex-works/ total duration
Estimated time of arrival on site

Program: Date material required on site
Latest date for order

I hereby certify that the above submitted items have been reviewed in detail and are correct and in full conformity with the Contract drawings and specifications.

Submitted by: **Eng. Wesam Taweos** Signature: *[Signature]*

4. Engineer's Representative comments:

- CURB STONE Dimensions and area of application as per approved shop drawings.
- Curb stone color, finish & Texture as per Dar Arch. Representative on site approval.
- Random samples taken for material delivered on site for testing before installation as per Egyptian standard requirement (Compressive strength & Absorption)
- Final approval subject to successful mockup on site

Signature: *[Signature]* Date: **29/7/19**

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.

SG El Soadaa Group
(Construction and Building)
130 JUL 2019
Received
بولع العاصمة الإدارية الجديدة

PROJECT PARTNERS

Submittal for approval of materials

dar Dar Al-Muhandazin
28 JUL 2019
RECEIVED Date: 28/07/2019
Request no: P1104-0400S Time: SOD-MAT-AAR-0342 Rev 00

Project no. & title: Project No.E16104-0400S/T-04 Ministerial Buildings On Plot 9B&10B

Employer:	Engineer: dar	Contractor: SG El Soadaa Group
-----------	-------------------------	---

1. Material description (one item only on this form):

البريدرات الخرسانية مسابية الصب

1 CD

1 SAMPLE

Area of application: All Building

Drawing ref.: N/A

Specification Ref.: 2771

B.O.Q. ref. no.: 2771

Standards: N/A

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name:

EGY-CRETE

Address:

قاعة Y1/FA المنطقة الصناعية منبته بدر

Local agent:

SHEROUK FOR CEMENT PRODUCTS

3. Delivery:

Country of origin:

EGYPT

Availability:

☒ Locally Manufactured

☐ Overseas

Delivery:

Ex-works/ total duration

Estimated time of arrival on site

Program:

Date material required on site

Latest date for order

We certify that the above submitted items have been reviewed in detail and are correct and in full conformity with the Contract drawings and specifications

Submitted by:

Eng. Wesam Tawoos

Signature:

4. Engineer's Representative comments:
- CURB STONE Dimensions and area of application as per approved shop drawings.
 - Curb stone color, finish & Texture as per Dar Arch. Representative on site approval.
 - Random samples taken for material delivered on site for testing before installation as per Egyptian-standard requirement (Compressive strength & Absorption)
 - Final approval subject to successful mockup on site

Signature:

Date:

29/7/19

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.



PROJECT PARTNERS

Submittal for approval of materials

21 JUL 2019
RECEIVED

Date: 21-07-19

Request no: HAC/MAT/AAR/292 Rev.00

Project no. & title: E16104-04005A-02/Ministerial Buildings on Plots 5A & 6A

Employer: ACUD ADMINISTRATIVE CAPITAL العاصمة الإدارية للتنمية العمرانية	Engineer: dar	Contractor: HASSAN ALLAM CONSTRUCTION
--	-------------------------	--

1. Material description (one item only on this form):

(No Sample) بلاط انترلوك اللون مقاس 6*10*20

Area of application: land scape

Drawing ref.: G01-L-1-00-3-X-FC-00.REV02

B.O.Q. ref. no.: 2780

Specification Ref.: 2780

Standards: as per attached

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate

Attached: 1 Pages A4

2. Manufacturer / supplier

Company Name: egy-crete

Address: 38/39 ارض - المنطقة الصناعية - الحرفية ب- 250 دكان - طريق الروبيك، مدينة بدر

Local agent: egy-crete

3. Delivery:

egypt

Country of origin:

Availability

☒ Locally Manufactured

☐ Overseas

Delivery

Ex-works/ total duration

Estimated time of arrival on site

Program

Date material required on site

Latest date for order

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by: Eng. Mostafa Shalaby

Signature:

4. Engineer's Representative comments:

- interlock Dimensions and area of application as per approved shop drawings.
- interlock color, finish & Texture as per Dar Arch. Representative on site approval.
- Random samples taken for material delivered on site for testing before installation as per Project specs. requirement (Compressive strength & Absorption)
- Final approval subject to successful mockup on site.
- Absorption not exceed 5% after 24 hours.

F.Maher

Signature

Date

A. Ra

28/7/19

- ☐ Approved
- ☒ Approved as noted
- ☐ Revise and resubmit
- ☐ Rejected
- ☐ Sample required
- ☐ Tests required
- ☐ Additional information required
- ☐ Manufacturer's guarantee required

Approval: shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents

Site master

29 JUL 2019

HAC- DC
Ministries District project

Received

29 JUL 2019

HAC- DC
Ministries District project

PROJECT PARTNERS

Submittal for approval of materials



Date: 21-07-19

Request no: HAC/MAT/AAR/292 Rev.00

Project no. & title: E16104-050054-02/Ministerial Buildings on Plots 5A & 6A

Employer: 	Engineer: 	Contractor:
---------------	---------------	-----------------

1. Material description (one item only on this form) :

(No Sample) بلاط اقترلوك اللون مقاس 6*10*20

Area of application : land scape

Drawing ref. G01-L-1-00-3-X-FC-00.REV02

B.O.Q. ref. no.: 2780

Specification Ref. : 2780

Standards : as per attached

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate

Attached : 1 Pages A4

2. Manufacturer / supplier

Company Name : egy-crete

Address : 38/39 ارض - المنطقة الصناعية - الحرفية ب- 250 قن طريق الروبيكي، سفينة بدر

Local agent : egy-crete

3. Delivery :

egypt

Country of origin :

Availability

☒ Locally Manufactured

☐ Overseas

Delivery : Ex-works/ total duration

Estimated time of arrival on site

Program : Date material required on site

Latest date for order

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : Eng. Mostafa Shalaby

Signature:

4. Engineer's Representative comments:

- interlock Dimensions and area of application as per approved shop drawings.
- interlock color, finish & Texture as per Dar Arch. Representative on site approval.
- Random samples taken for material delivered on site for testing before installation as per Project specs. requirement (Compressive strength & Absorption)
- Final approval subject to successful mockup on site.
- Absorption not exceed 5% after 24 hours.

F.Maher

Signature

Date

28/7/19

- ☐ Approved
- ☒ Approved as noted
- ☐ Revise and resubmit
- ☐ Rejected
- ☐ Sample required
- ☐ Tests required
- ☐ Additional information required
- ☐ Manufacturer's guarantee required

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents

Site master

29 JUL 2019

HAC- DC
Ministries District project

Received

29 JUL 2019

HAC- DC
Ministries District project

PROJECT PARTNERS

Sub-Contractor's Approval

Date : 20/04/2022
Ref.: SC-C-EDECS-063-0042
Rev.: 00
EDECS Ref. 0111

dar Dar Al-Handasah (Share and Partners)
21 APR 2022
RECEIVED

Project No. & Title : E20046-0200S - Multi Purpose Terminal 55/62 - Alexandria port

Employer:
EGMPT
— EGYPTIAN GROUP FOR —
MULTI PURPOSE TERMINALS

Engineer:
dar

Contractor: EDECS
EL Dawlia for Engineering & Contracting

EDECS

1. Sub-Contractor's particulars

Company Name : EGY-CRETE

Company Line or works : Interlock Supplier

Address : المنطقة الصناعية - الحريقة ب- 250 قدان - طريق الروبيكي - مدينة بدر - 38/39

The following prequalifying documents should be enclosed :

☐ Commercial Register
☐ Present Works

☐ Founding Contract
☐ Company Staff

☐ Summary of Experience
☐ Company Equipment

☐ Financial Status

2. Sub-Contracted works


Section of the Works : Yard

BOQ Items : —

Total Value of Sub-Contract (in Contract Rates) :

Cumulative Value of Sub-Contracted works to-date (in Contract Rates) :


Submitted by: Eng. Mostafa Noaman

Signature: 

3. Engineer's Representative comments

** No objection on EGY-CRETE subject to:*

- The used products must meet the project specifications.*
- Submit samples for testing in an independent lab. as per the project requirements.*
- The final approval shall be after achieving all requirements as per the project specs.*

The Engineer's Representative:
Signature:  Date: 24/4/2022

PROJECT PARTNERS



DOCUMENTS SUBMITTAL REQUEST / طلب اعتماد مستندات

Client: **AL AHLY SABBOUR DEVELOPMENTS** Consultant: **SABBOUR CONSULTING** Contractor: **Civil Home**

Contract No: **Green Square / Green Valley** Project: **Green Square / Green Valley**

Request No: **52** REV. NO: **1** Date: **10/5/2023**

For approval: ☐ For information: ☐

Field	Field	Field	Field	Field
Technical reports	Calulations	Quality documents	Time schedule	
Other	Tests reports	Healthy and safety documents	Cash flow plan	

SN	Document type	Description	Attachments	Notes
1	EGY-CRETE	Data sheet		

Contractor representative (Signature/Name/Position): **Contractor project manager** (Signature/Name/Position): **Received by Consultant** (Signature/Name/Position):

Approval actions: A-APPROVED () B-APPROVED AS NOTED () C-REVISE & RESUBMIT () D-REJECTED ()

APPROVAL COMMENTS: *كما موضح في التور... Vendor list... EGYCRETE*

Signatures: *Eng. Hany Raly* (Contractor representative), *Eng. Hany Raly* (Contractor project manager), *Eng. Hany Raly* (Received by Consultant)

ROWAD
MODERN ENGINEERING

ECG م. ٥/٢٠٢٢
ENGINEERING CONSULTANTS GROUP S.A.

طلب اعتماد مواد

MS/R5/Z04/LS/0026	رقم الطلب: Rev.01	المالك : هيئة المجتمعات العمرانية	مشروع الحي السكني R05 - (Zone-04) بالعاصمة الإدارية الجديدة
صفحة 1/2	التاريخ : 26/12/2022	الإستشاري : ECG	المقاول : شركة رواد الهندسة الحديثة

1. قسم التقديم:

☐ انشائي ☐ معماري ☐ كهرباء ☐ صحي ☐ تكييف ☐ حريق ☒ تنسيق موقع عام

2. صفة التقديم:

1	عينات (عدد 19)	2	اختبارات	3	مواصفات فنية	4	سابقة أعمال	5	كتالوج	6	الخرى
---	----------------	---	----------	---	--------------	---	-------------	---	--------	---	-------

3. التقديم بالفرض

☐ للنم ☒ للاعتماد ☐ الأخرى

4. الموقع:

المنطقة : Zone 04 التجمع : عام المبنى : عام

5. تفاصيل التقديم: أعمال بلاط الأرضية المتداخلة (الإنترلوك)

البيانات / الوصف	النوع / المورد	الرقم مرجع المستندات	عدد الترخيص	مراجع العقد	الإعتماد
إجهاد 250 كجم/سم² سمك 6 سم					
1	بلاط إنترلوك 10*10 سم سمك 6 سم تشطيب خشن رمادي فاتح	EGY Crete	2	2780	2780
2	بلاط إنترلوك 10*10 سم سمك 6 سم تشطيب خشن رمادي غامق	EGY Crete	2	2780	2780
3	بلاط إنترلوك 10*10 سم سمك 6 سم تشطيب خشن بيج	EGY Crete	2	2780	2780
4	بلاط إنترلوك 10*10 سم سمك 6 سم تشطيب خشن أحمر	EGY Crete	2	2780	2780
5	بلاط إنترلوك 10*20 سم سمك 6 سم تشطيب خشن رمادي فاتح	EGY Crete	2	2780	2780
6	بلاط إنترلوك 10*20 سم سمك 6 سم تشطيب خشن رمادي غامق	EGY Crete	2	2780	2780
7	بلاط إنترلوك 10*20 سم سمك 6 سم تشطيب خشن بيج	EGY Crete	2	2780	2780
8	بلاط إنترلوك 10*20 سم سمك 6 سم تشطيب خشن أحمر	EGY Crete	2	2780	2780
9	بلاط إنترلوك 10*20 سم سمك 6 سم تشطيب خشن أسود	EGY Crete	2	2780	2780

ملاحظات المقاول:

- لزوم تنسيق الموقع العام والأرصعة والطرق
 - إجهاد الكسر طبقاً لمواصفة المشروع (250 كجم/سم² سمك 6 سم / 350 كجم/سم² سمك 8 سم / 450 كجم/سم² سمك 8 سم)
 - مرفق عينات لتدرجات الألوان (رمادي فاتح - رمادي غامق - أسود - بيج - أحمر)

مدير المكتب الفني الاسم : التوقيع :	مهندس المكتب الفني الاسم : التوقيع :
---	--

ملاحظات الإشراف:

3 AB
 1 2023

☐ (A) معتمد ☒ (B) معتمد مع ملاحظات ☒ (C) بعد تقديمه بعد استلام الملاحظات ☐ (D) مرفوض ولا بعد تقديمه	ملاحظات الإشراف: لمارت مع المرفق
--	---

ROWAD

RECEIVED

26 DEC 2022

Project No 2550

الاسم :
استلام الاستشاري
الاسم :
التوقيع :

CONCRETE PLUS Engineering - Construction

ECG ENGINEERING CONSULTANTS GROUP S.A.

م. جمال محمد السيد / م. جمال محمد السيد

طلب اعتماد مواد

رقم الطلب: MS/R5/Z09/Roads/Arch/010 Rev.00
صفحة: 1-1
التاريخ: 2022/12/27

المالك: هيئة المجتمعات العمرانية
الاستشاري: جماعة المهندسين
الاستشاريين: ECG

المقاول: شركة كونكريت بلس

1. قسم التقديم: ☐ تشيئي ☐ مصاري ☐ كهرباء ☐ صحي ☐ تكييف ☐ حريق ☐ طرق

2. صفة التقديم: ☐ عينات (5 عينات) ☐ خامات ☐ كتلوج (Data Sheet) ☐ 4 ☐ أخرى

3. التقديم بالغرض: ☐ للعلم ☐ للاعتماد ☐ أخرى

4. الموقع: المنطقة: Zone 09 التجمع: General المبنى:

5. تفاصيل التقديم:

م	البيان / الوصف	النوع / المورد	عدد التسليم	رقم مراجع المستندات	مراجع العقد	كود الاعتماد
1	طلب اعتماد انترلوك 20 x 10 x 8 اجهاد 450 م لزوم اعمال الطرق (رمادي فاتح)	شركة ايجي كريت للمنتجات الاسمنتية	3			
2	طلب اعتماد انترلوك 20 x 10 x 8 اجهاد 450 م لزوم اعمال الطرق (رمادي غامق)	شركة ايجي كريت للمنتجات الاسمنتية	3			
3	طلب اعتماد انترلوك 20 x 10 x 8 اجهاد 450 م لزوم اعمال الطرق (أسود)	شركة ايجي كريت للمنتجات الاسمنتية	3			
4	طلب اعتماد انترلوك 20 x 10 x 8 اجهاد 450 م لزوم اعمال الطرق (أحمر)	شركة ايجي كريت للمنتجات الاسمنتية	3			
5	طلب اعتماد انترلوك 20 x 10 x 8 اجهاد 450 م لزوم اعمال الطرق (بيج)	شركة ايجي كريت للمنتجات الاسمنتية	3			

ملاحظات المقاول: مرفق: Data Sheet + عدد (5) عينات + الاختبارات + اعتماد الشركة في ECG + المقاييس + المواصفة.

مدير المشروع: م. / حسن مصطفى
التوقيع:

مدير المكتب الفني: م. / مي مصطفى
التوقيع:

ملاحظات الاستشاري: المستند المقدم للمراجعة هو المستند رقم 1845/ASTM C418-18A
مرفق مع ملاحظات
بعد تقديمه بعد استيفاء الملاحظات
مرفوض ولا يعاد تقديمه

التاريخ: 2022/12/26

اسلام المقاول: م. / جمال محمد السيد
التوقيع:

اسلام الاستشاري: م. / جمال محمد السيد
التوقيع:

02 JAN 2023

RECEIVED
27 DEC 2022
م. / جمال محمد السيد
Project No 2586

PROJECT PARTNERS



MATERIAL SUBMITTAL (MS)

Project Name : VILLETTE
Project No. : 301-002-CC-P43
Employer : SOREAL
Project Manager : Eng. mohamed hamdy

Package : Club S - Zones C & D
Phase : Zone D
Supervision Consultant : R.M.C
Contractor : Delta for road construction

From : DELTA
To : Raffat Miller Consulting (RMC)
Attn. : Eng. Ahmed Ragab
Subject : 60 mm thick, interlocking pavers, 300*300 mm, dark & light gray color on 50mm

Date : 20/3/2023
Submittal No. : 1089-MS-DEL-RMC-ARCH-P43-002
Rev: 01

Material / Equipment For Approval: Interlocking pavers 60 mm
Description: - Interlocking 300*300 mm, dark gray color on 50mm
Specification Reference : _____ Sample Quantity: 2 Bill of Quantities Reference: _____

Manufacturer's Details : egypt ceret
Manufacturer: EGY CERET
Model Number : _____
Country of Origin: _____
Storage Location : _____
Bill of loading: _____

Seal number: _____
Certificate of Origin: _____
Date of arrival on site: _____

21 MAR 2023
TIME: RECEIVED

Action Code Legend:
(A) Approved (B) Approved as Noted (C) Revise and Resubmit (D) Rejected

Notes:
• Exposed Finishing materials must be approved by Employer, Embedded materials must be approved by Employer in case change of vendor
• Production, supply and /or implementation shall proceed only when action code is A / or B.
• Regarding action code C, resubmittal shall be within the limit set in the contract.
• Review does not relieve the contractor from responsibility of compliance with all requirements of contract documents.
• If rejected please see comments.

Consultant Comments:

Inspection Report:	Yes/No	Initials Inspector	Engineer
1- Physical damage?	No		
2- Details given above correct?	Yes		
3- Accessories included?	No		

Remarks:
Technically approved
final approval is subjected to the Employer's approval.

Actions required from Contractor:
The contractor must submit all necessary tests from authorized lab such as: compressive, friction, etc. absorption.

Approved

Resident Engineer: Ahmed Ragab
Employer Representative: [Signature]

PROJECT PARTNERS



MATERIAL SUBMITTAL (MS)

Project Name : THE ESTATES SODIC	Date : 21/05/2023	
Employer : AL YOSR	Submittal No. : AL YOSR/MS/EXP/INFRA-ROADS/0012/00	
Project Manager : Eng. Ahmed Nabih	Contract : YSR-003-CC-P1	
Consultant : Engineering Consulting Bureau ECB	From : EXPERTS	
Contractor : EXPERTS	To : ECB	

Material/Equipment Description: Interlock 20*10*8 cm Grey
Interlock 20*10*8 cm Black
Interlock 10*10*8 cm Black
Location: Roads

Submittal Category:

☐ Architecture – (ARCH)	☐ Civil/Structure – (ST)	☐ Survey – (SURV)
☐ MEP – (MEP)	☐ Fire Protection – (FF)	☐ Plumbing – (PL)
☐ HVAC – (HVAC)	☐ Electrical – (ELECT)	☐ Light Current – (E-LC)
☒ Infrastructure – (INFRA)	☐ Mobilization – (MOB)	☐ Landscape – (LS)
☐ Safety – (SAF)	☐ Elevators – (ELEV)	☐ General – (GEN)

Spec. Reference : 02780	B.O.Q Reference : Attachment	Quantity -BOQ
Manufacturer : EGY CRETE	Date of arrival on site : _____	
Model Number : Attachment	Serial number : Attachment	
Country of Origin : Egypt	Certificate of origin : _____	
Storage Location : _____	Bill of lading : _____	

Attachments:

☐ Hard Copy () Sheet ☒ Soft Copy (CD) ☒ Samples (3)

Note: Please Clarify the Attachments if any.

Action Code Legend:

(A) Approved (B) ☒ Approved as Noted (C) Revise and Resubmit (D) Rejected

Notes:

- Production, supply and/or implementation shall proceed only when action code is A / or B.
- Regarding action code C, resubmittal shall be within the limit set in the contract.
- Review does not relieve the contractor from responsibility of compliance with all requirements of contract documents.
- If rejected please see comments.

Consultant Comments:

* Refer to attached comments.

Engineer

PROJECT PARTNERS



MATERIAL SUBMITTAL (MS)			
Project Name	: THE ESTATES SODIC	Date	: 21/05/2023
Employer	: ALYOSR	Submittal No.	: ALYOSR/MS/EXP/INFRA-ROADS/0012/00
Project Manager	: Eng. Ahmed Nabih	Contract	: YSR-003-CC-P1
Consultant	: Engineering Consulting Bureau ECB	From	: EXPERTS
Contractor	: EXPERTS	To	: ECB
Material/Equipment Description: Interlock 20*10*8 cm Grey Interlock 20*10*8 cm Black Interlock 10*10*8 cm Black Location: Roads			
Submittal Category: ☐ Architecture – (ARCH) ☐ MEP – (MEP) ☐ HVAC – (HVAC) ☒ Infrastructure – (INFRA) ☐ Safety – (SAF)	☐ Civil/Structure – (ST) ☐ Fire Protection – (FF) ☐ Electrical – (ELECT) ☐ Mobilization – (MOB) ☐ Elevators – (ELEV)	☐ Survey – (SURV) ☐ Plumbing – (PL) ☐ Light Current – (E-LC) ☐ Landscape – (LS) ☐ General – (GEN)	
Spec. Reference	: 02780	B.O.Q Reference	: Attachment
Manufacturer	: EGY CRETE	Date of arrival on site	: _____
Model Number	: Attachment	Serial number	: Attachment
Country of Origin	: Egypt	Certificate of origin	: _____
Storage Location	: _____	Bill of lading	: _____
Attachments: ☐ Hard Copy () Sheet ☒ Soft Copy (CD) ☒ Samples (3)			
Note: Please Clarify the Attachments if any. Action Code Legend: (A) Approved (B) Approved as Noted (C) Revise and Resubmit (D) Rejected			
Notes: - Production, supply and /or implementation shall proceed only when action code is A / or B. - Regarding action code C, resubmittal shall be within the limit set in the contract. - Review does not relieve the contractor from responsibility of compliance with all requirements of contract documents. - If rejected please see comments.			
Consultant Comments: <i>* Refer to attached comments.</i> Engineer			

[illegible]

Submittal for approval of materials

Date: 20/01/2020
Request no: SOD-MAT-AAR-0341 Rev 03

Project no. & title: Project No.E16104-0400S/T-04 Ministerial Buildings On Plot 9B&10B

Employer:	Engineer: dar	Contractor: SG El Soadaa Group
-----------	-------------------------	---

1. Material description (one item only on this form) :

بلاط الرصف الخرستى (الترلوك)

1 CD

no SAMPLE

Area of application : اعمال الموقع العام
Drawing ref. : N/A B.O.Q. ref. no.: 2780
Specification Ref. : 2780 Standards: N/A
Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name : EGY-CRETE
Address : 17 SUADI COMPANY BUILDING NOZHA STREET GOLF - EGYPT
Local agent : SHEROUK FOR CEMENT PRODUCTS

dar Dar Al-Handasah

Project No: E16104-0400S-

Received:

Distribution

Action

Int

A.Kh

A.Ram

M.B

3. Delivery :

Country of origin : EGYPT
Availability : ☒ Locally Manufactured ☐ Overseas

Delivery : Ex-works/ total duration
Estimated time of arrival on site

Program : Date material required on site
Latest date for order

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the Contract drawings and specifications

Submitted by : Eng. Mena

Signature: **SG**
El Soadaa Group
(Construction and Building)

4. Engineer's Representative comments:

Subject to approval work up
at site with the required
data & shape.

Add initial tests you deliver

28/1/2020

Signature: A.Ra Date: 28/1/20

- ☒ Approved
- ☒ Approved as noted
- ☐ Revise and resubmit
- ☐ Rejected
- ☐ Sample required
- ☐ Tests required
- ☐ Additional information required
- ☐ Manufacturer's guarantee required

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.



PROJECT PARTNERS

Submittal for approval of materials

dar Dar Al-Hindiyah
28 JUL 2019
RECEIVED Date: 28/07/2019
Request No. E16104-0400S Time SOD-MAT-AAR-0342 Rev 00
Prj. No. E16104-0400S

Project no. & title: Project No.E16104-0400S/T-04 Ministerial Buildings On Plot 9B&10B

Employer:	Engineer: dar	Contractor: SG El Soadaa Group
-----------	-------------------------	---

1. Material description (one item only on this form):

البريدرات الخرسانية سابقة الصب
1 CD
1 SAMPLE
Area of application: **All Building**
Drawing ref.: **N/A**
Specification Ref.: **2771**
B.O.Q. ref. no.: **2771**
Standards: **N/A**
Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name: **EGY-CRETE**
Address: **لبنان ٢٩/٢٨ المنطقة الصناعية مدينة بدر**
Local agent: **SHEROUK FOR CEMENT PRODUCTS**

3. Delivery:

Country of origin: **EGYPT**
Availability: ☒ Locally Manufactured ☐ Overseas
Delivery: Ex-works/ total duration
Estimated time of arrival on site
Program: Date material required on site
Latest date for order

Signature: **Eng. Wesam Tawoos**
Date: **29/7/19**

4. Engineer's Representative comments:

- CURB STONE Dimensions and area of application as per approved shop drawings.
- Curb stone color, finish & Texture as per Dar Arch. Representative on site approval.
- Random samples taken for material delivered on site for testing before installation as per Egyptian standard requirement (Compressive strength & Absorption)
- Final approval subject to successful mockup on site

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.

SG El Soadaa Group
(Construction and Building)
130 JUL 2019
Received
بوقع العاصمة الإدارية الجديدة